

Energy Performance Certificate



Address of dwelling and other details

FLAT 3
2 COLONSAY WAY
EDINBURGH
EH5 1FB


Dwelling type:
Name of approved organisation:
Membership number:
Date of certificate:
Reference number:
Type of assessment:
Total floor area:
Main type of heating and fuel:

Mid-floor flat
Elmhurst Energy Systems Ltd
EES/008430
22 August 2012
4712-7028-5000-0512-0086
RdSAP, existing dwelling
50 m²
Boiler and radiators, mains gas

Elmhurst Energy Systems Ltd
14 Union Street
Glasgow, G1 3QQ
T: +44 (0)141 221 7993
F: +44 (0)141 204 4064
E: enquiries@elmholm.co.uk


This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2009 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO₂) emissions. CO₂ is a greenhouse gas that contributes to climate change.



The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

Approximate current energy use per square metre of floor area: 105 kWh/m²per year
Approximate current CO₂emissions: 20 kg/m²per year



The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating the less impact it has on the environment.

Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above.

- 1 Low energy lighting for all fixed outlets

A full energy report is appended to this certificate



Remember to look for the Energy Saving Trust Recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.
Information from this EPC may be given to the Energy Saving Trust to provide advice to householders on financial help available to improve home energy efficiency.

Energy Report



The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of Elmhurst Energy Systems Ltd. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been entered on a national register.

Assessor's name: Mr. Kenneth Telfer
Company name/trading name: Russell & Telfer Limited
Address: 3 Annafreuch Kinross Perth & Kinross KY13 0LF
Phone number: 01577 850337
Fax number: 01577 850337
E-mail address: k_telfer@btinternet.com
Related party disclosure: No related party

114 Union Street
Glasgow, G1 3QQ
T: +44 (0)141 221 7993
F: +44 (0)141 204 4064
E: enquiries@fineholm.co.uk

11 Grove Street
Edinburgh, EH3 8AF
T: +44 (0)131 221 9131
F: +44 (0)131 221 1144
E: edinburghenquiries@fineholm.co.uk

www.fineholm.co.uk

Estimated energy use, carbon dioxide (CO₂) emissions and fuel costs of this home

	Current	Potential
Energy use	105 kWh/m ² per year	92 kWh/m ² per year
Carbon dioxide emissions	1.0 tonnes per year	0.9 tonnes per year
Lighting	£66 per year	£33 per year
Heating	£178 per year	£182 per year
Hot water	£70 per year	£70 per year

The figures in the table above have been provided to enable prospective buyers and tenants to compare the fuel costs and carbon emissions of one home with another. To enable this comparison the figures have been calculated using standardised running conditions (heating periods, room temperatures, etc.) that are the same for all homes, consequently they are unlikely to match an occupier's actual fuel bills and carbon emissions in practice. The figures do not include the impacts of the fuels used for cooking or running appliances, such as TV, fridge etc.; nor do they reflect the costs associated with service, maintenance or safety inspections. Always check the certificate date because fuel prices can change over time and energy saving recommendations will evolve.

About the building's performance ratings

The ratings on the certificate provide a measure of the buildings overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use standard occupancy assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

Registered office:
114 Union St Glasgow G1 3QQ
Company No:
Glasgow SC154047, Edinburgh SC260949
VAT Reg No:
Glasgow 659063310, Edinburgh 865566384



Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology, 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the physical condition of any element. Assumed means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction

Element	Description	Current Performance	
		Energy Efficiency	Environmental
Walls	Cavity wall, as built, insulated (assumed)	★★★★★	★★★★★
Roof	(another dwelling above)	—	—
Floor	(other premises below)	—	—
Windows	Fully double glazed	★★★★☆	★★★★☆
Main heating	Boiler and radiators, mains gas	★★★★☆	★★★★☆
Main heating controls	Programmer, room thermostat and TRVs	★★★★☆	★★★★☆
Secondary heating	None	—	—
Hot water	From main system	★★★★☆	★★★★☆
Lighting	No low energy lighting	☆☆☆☆☆	☆☆☆☆☆
Current energy efficiency rating		C 80	
Current environmental impact (CO₂) rating		B 86	

Union Chambers
 114 Union Street
 Glasgow, G1 3QU
 T: 01441 204 4064
 F: 01441 204 4064
 E: enquiries@fineholm.co.uk
 www.fineholm.co.uk

Low and zero carbon energy sources

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere. There are none applicable to this home.





Recommended measures to improve this homes energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether the property experts permissions are required such as a building warrant, planning consent or listed building restrictions. The indicative costs are representative for most properties but may not apply in a particular case.

Lower cost measures	Indicative Cost	Typical savings per year	Ratings after improvement	
			Energy Efficiency	Environmental Impact
1 Low energy lighting for all fixed outlets	£18	£29	B 82	B 88
Total		£29		

Union Chambers
 114 Union Street
 Glasgow G1 3DD
 T: +44 (0)131 221 7993
 F: +44 (0)131 221 0000
 E: enquiries@fineholm.co.uk
 11 Grove Street
 Edinburgh, EH3 8AF
 T: +44 (0)131 221 9131
 F: +44 (0)131 221 1144
 E: edinburghenquiries@fineholm.co.uk
www.fineholm.co.uk

Potential energy efficiency rating	B 82
Potential environmental impact (CO ₂) rating	B 88

Further measures to achieve even higher standards

None



Registered office:
 114 Union St Glasgow G1 3DD
 Company No:
 Glasgow SC154047, Edinburgh SC280949
 VAT Reg No:
 Glasgow 659053310, Edinburgh 863566284

About the cost effective measures to improve this home's performance ratings



the **property** experts

If you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

Lower cost measures

These measures are relatively inexpensive to install and are worth tackling first. The indicative costs of measures included earlier in this EPC include the costs of professional installation in most cases. Some of them may be installed as DIY projects. DIY is not always straightforward, and sometimes there are health and safety risks, so take advice before carrying out DIY improvements.

1 Low energy lighting

Replacement of traditional light bulbs with energy saving recommended ones will reduce lighting costs over the lifetime of the bulb, and they last up to 12 times longer than ordinary light bulbs. Also consider selecting low energy light fittings when redecorating; contact the Lighting Association for your nearest stockist of Domestic Energy Efficient Lighting Scheme fittings.

Union Chambers
Glasgow G1 3DD
T: +44 (0)141 221 9131
F: +44 (0)141 204 4064
E: enquiries@fineholm.co.uk

11 Grove Street
Edinburgh EH3 6AE
T: +44 (0)131 221 9131
F: +44 (0)141 221 9131
E: edinburgh@fineholm.co.uk
www.fineholm.co.uk

About the further measures to achieve even higher standards

Not applicable

What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO₂ emissions.
- If you have a conservatory or sunroom, avoid heating it in order to use it in cold weather and close doors between the conservatory and dwelling.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- Close your curtains at night to reduce heat escaping through the windows.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme. Minimise the use of tumble dryers and dry clothes outdoors where possible.
- Check the draught-proofing of windows and replace it if appropriate.
- If you have unused open chimneys consider blocking them off (making provision for a ventilation opening and a cowl on top of the chimney to avoid dampness).

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call 0800 512 012 or visit www.energysavingtrust.org.uk.



Registered office:
114 Union St Glasgow G1 3DD
Company No:
Glasgow SC154047, Edinburgh SC280949
VAT Reg. No:
Glasgow 659083310, Edinburgh 865566284